



**BUREAU  
VERITAS**

# Certificado de conformidade

**Requerente:** SMA Solar Technology AG  
Sonnenallee 1  
34266 Niestetal  
Alemanha

**Produto:** Microgerador em paralelo com redes de distribuição pública de baixa tensão

**Modelo:** SHP75-10  
STPS60-10

## Utilização de acordo com os regulamentos:

Dispositivo de desconexão automática com monitorização da rede trifásica para sistemas com um circuito paralelo trifásico através de um inversor na alimentação pela rede pública. O dispositivo de desconexão automática é parte integrante do inversor anteriormente mencionado.

## Regras e normas aplicadas:

EN 50438:2013 / PN EN 50438:2015

Requisitos para as instalações de microprodução destinadas a serem ligadas em paralelo com as redes públicas de distribuição de baixa tensão

EN 50438:2013 / PN EN 50438:2015 com as definições de protecção de interface padrão para Portugal. O SHP75-10, STPS60-10 é dimensionado para uma corrente máxima >16 A por fase, mas todos os requisitos básicos da norma estão cumpridos.

*Limites básicos:*

*sobretensão 458,1*

*subtensão 383,6*

*sobrefrequência 52,0 Hz*

*subfrequência 47,5 Hz*

Aquando da emissão deste certificado, o conceito de protecção de interface de um produto representativo anteriormente mencionado corresponde a especificações de segurança válidas para a utilização especificada, de acordo com os regulamentos. Os testes e certificação foram realizados de acordo com a norma ISO / IEC sistema 5 – Guia 67:2004.

**Número de relatório:** 14TH0075\_EN50438\_1

**Número de certificado:** U18-0449

**Data de emissão:** 2018-08-29 **Válido até:** 2023-08-28

**Órgão de certificação**



Holger Schaffer



Deutsche  
Akkreditierungsstelle  
D-ZE-12024-01-00

Órgão de certificação da Bureau Veritas Consumer Products Services Germany GmbH  
Acreditado nos termos da norma DIN EN ISO/IEC 17065

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

**Type Approval and declaration of compliance with the requirements of EN 50438.**

<b>Manufacturer / applicant:</b>	SMA Solar Technology AG Sonnenallee 1 34266 Niestetal Alemanha
<b>Micro-generator Type</b>	Grid-tied photovoltaic inverter
<b>Rated values</b>	SHP75-10 STPS60-10
<b>Maximum rated capacity</b>	75 kW
<b>Rated voltage</b>	400V 3P; PE
<b>Firmware version</b>	1.90
<b>Measurement period:</b>	2018-03-12 to 2018-03-22; 2018-08-03 to 2018-08-05

**Description of the structure of the power generation unit:**

The Solar converter converts DC voltage into AC voltage.

The input and output are protected by varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does provide galvanic separation from input to output (transformer). The output is switched off redundant by the high power switching bridge and a relay in series. This assures that the opening of the output circuit will also operate in case of one error.

The above stated micro-generators are tested according to the requirements in the EN 50438. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the EN 50438.

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

**Type testing of the interface protection**

Over-/under-voltage tests						
Phase1/2						
Parameter	Protection limit		Actual setting		Trip value (test result)	
	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]
Over-voltage stage 1	253,0	600*	253,0	600*	253,0	379*
Over-voltage stage 2	458,1	0,2	458,1	0,2	457,4	0,186
Under-voltage stage 1	338,6	1,5	338,6	1,5	338,4	1,500
Phase2/3						
Parameter	Protection limit		Actual setting		Trip value (test result)	
	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]
Over-voltage stage 1	253,0	600*	253,0	600*	253,0	379*
Over-voltage stage 2	458,1	0,2	458,1	0,2	457,4	0,193
Under-voltage stage 1	338,6	1,5	338,6	1,5	338,6	1,500
Phase3/1						
Parameter	Protection limit		Actual setting		Trip value (test result)	
	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]	Voltage [V]	Disconnection time [s]
Over-voltage stage 1	253,0	600*	253,0	600*	253,0	379*
Over-voltage stage 2	458,1	0,2	458,1	0,2	457,3	0,196
Under-voltage stage 1	338,6	1,5	338,6	1,5	338,5	1,500

Note.  
 Minimum operation time according to default interface protection:  
 Over-voltage stage 1 -  
 Over-voltage stage 2 0,1s  
 Under-voltage 1,2s

\* The over-voltage-stage 1 is a 10-min-mean-value according to EN 50160. The disconnection after detection of an overvoltage at the 10-min-mean-value takes place within 200ms.

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Over-/under-frequency tests						
Parameter	Protection limit		Actual setting		Trip value (test result)	
	Frequency [Hz]	Disconnection time [s]	Frequency [Hz]	Disconnection time [s]	Frequency [Hz]	Disconnection time [s]
<b>Over-frequency</b>	52,0	0,5	52,0	0,5	52,0	0,361
<b>Under-frequency</b>	47,5	0,5	47,5	0,5	47,5	0,390

Note.  
Minimum operation time according to default interface protection:  
Over-frequency 0,5 s  
Under-frequency 0,5 s

LoM test						
Method used	EN 62116					
Balancing load on islanded network	33% of -5% Q Test 22	66% of -5% Q Test 12	100% of -5% P Test 5	33% of +5% Q Test 31	66% of +5% Q Test 21	100% of +5% P Test 10
Trip time. Phase 1 fuse removed [ms]	416	396	496	426	416	466
Trip time. Phase 2 fuse removed [ms]	416	396	496	426	416	466
Trip time. Phase 3 fuse removed [ms]	416	396	496	426	416	466

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

**Type testing of a micro-generator**

**Operating range**

Test 1: U = 195,5 V; f = 47,5 Hz; P = 1,00 Sn; cosφ = 1

Test 2: U = 253,0 V; f = 51,5 Hz; P = 1,00 Sn; cosφ = 1

Test sequence	Voltage [V]	Frequency [Hz]	Output power [W]	Cos φ [1]
1	198,40	47,50	66035	0,999
2	253,30	51,50	73682	0,999

**Active power at under-frequency**

5-min mean value (each)	a) 50 ± 0,01 [Hz]	b) - 0,4 to - 0,5 [Hz]	c) - 2,4 to - 2,5 [Hz]
Frequency [Hz]:	50,00	49,60	47,60
Active power [kW]:	76,30	76,30	76,30
ΔP/PM [%] per 1 Hz:			0,0

**Power response to over-frequency**

1-min mean value [Hz]:	a) 50,00	b) 50,25	c) 50,70	d) 51,15	e) 50,70	f) 50,25	g) 50,00
<b>1. Measurement a) to g): Active power output &gt; 80% Pn</b>							
Frequency [Hz]:	50,09	50,24	50,69	51,13	50,68	50,24	49,98
PM [kW]:	N/A	73,12	59,83	46,56	59,83	73,12	N/A
PE60 [kW]:	74,24	73,47	60,06	46,70	60,12	73,15	74,81
ΔPE60/PM [%]:	N/A	0,46	0,31	0,19	0,39	0,05	N/A
<b>2. Measurement a) to g): Active power output 40% and 60% after freezing &gt; 80% Pn</b>							
Frequency [Hz]:	50,09	50,24	50,69	51,12	50,69	50,23	49,98
PM [kW]:	N/A	36,91	30,20	23,53	30,20	36,91	N/A
PE60 [kW]:	37,47	37,10	30,35	23,66	30,38	37,16	47,49
ΔPE60/PM [%]:	N/A	0,25	0,20	0,18	0,25	0,34	N/A
Limit ΔP/P1min:	+ 10 % of P <sub>M</sub>						



## Appendix E Type Verification Test Report

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Reactive power			
Uncontrollable reactive power			
Test Voltage	211,6V	230V	248,4V
Output power			
25% PN	0,999	0,999	0,999
50% PN	0,999	0,999	0,999
75% PN	0,999	0,999	0,999
100% PN	0,999	0,999	0,999
Limit	>0,95	>0,95	>0,95


Controllable reactive power				
Inductive (supply reactive power)				
Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ) [1]	DC Power [W]
0% - 10%	3243,11	-33556,62	-0,10	3853,96
10% - 20%	10074,87	-33466,30	-0,29	10701,71
20% - 30%	16783,75	-33375,08	-0,45	17459,70
30% - 40%	23525,70	-33283,50	-0,58	24284,18
40% - 50%	30920,56	-33182,84	-0,68	31808,89
50% - 60%	36841,89	-33102,20	-0,74	37844,23
60% - 70%	43456,05	-33013,02	-0,80	44606,17
70% - 80%	50748,93	-32915,56	-0,84	52101,61
80% - 90%	58167,94	-32826,99	-0,87	59731,48
90% - 100%	64607,58	-32728,32	-0,89	66402,20
Capacitive (supply reactive power)				
Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ) [1]	DC Power [W]
0% - 10%	3184,80	32752,49	0,10	3847,36
10% - 20%	9978,21	32842,66	0,30	10658,78
20% - 30%	16920,87	32733,69	0,46	17650,34
30% - 40%	23672,20	32822,27	0,59	24486,02
40% - 50%	30914,62	32692,98	0,69	31856,50
50% - 60%	36820,96	32698,43	0,75	37878,52
60% - 70%	43583,43	32789,71	0,80	44792,91
70% - 80%	50931,88	32887,05	0,84	52345,39
80% - 90%	57413,00	32972,80	0,87	59028,32
90% - 100%	64525,55	33069,24	0,89	66402,44
Reactive power supply with set point Q = 0				
Power-BIN	Active power [W]	Reactive power [Var]	Power factor (cos φ) [1]	DC Power [W]
0% - 10%	3005,03	334,84	0,99	3093,18
10% - 20%	10500,35	236,32	1,00	10669,38
20% - 30%	17152,72	149,69	1,00	17408,43
30% - 40%	23829,14	59,89	1,00	24201,20
40% - 50%	31211,02	39,74	1,00	31739,98
50% - 60%	37638,55	123,43	1,00	38302,36
60% - 70%	45542,00	227,58	1,00	46415,98
70% - 80%	52637,23	322,68	1,00	53722,77
80% - 90%	57581,33	390,84	1,00	58841,61
90% - 100%	64133,65	479,98	1,00	65627,83

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

**Diagram of inductive reactive power absorption**



Q adjustment			
	Reactive power set point Q [%]	Measured reactive power Q/Pn [%]	Deviation compared to setpoint $\Delta Q / PN$ [%]
- Qmin	-48,43	-48,33%	0,10%
0	0	0,76%	0,76%
+ Qmax	+48,43	49,85%	1,42%

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Connection and starting to generate electrical power		
Test according EN 50438 with standard setting	Min. voltage for connection to grid:	196V
	Max. voltage for connection to grid:	253V
	Min. frequency for connection to grid:	47,50Hz
	Max. frequency for connection to grid:	50,05Hz
	Observation time ( $\geq 60s$ )	60s
<b>Test</b>		
<b>Voltage conditions</b>		
a) Start up for voltage range	<84% $U_n$ for twice of observation time	>111% $U_n$ for twice of observation time
Connection:	No connection	No connection
Limit:	No connection allowed	
b) In voltage range at start-up	$\geq 84\% U_n$ within twice setting observation time	$\leq 111\% U_n$ within twice setting observation time
Reconnection time [s]	61	61
Limit:	Connected after setting observation time ( $\geq 60s$ )	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min.	
c) In voltage range after voltage failure	$\geq 84\% U_n$ for twice of setting observation time	$\leq 111\% U_n$ for twice of setting observation time
Reconnection time [s]	61	61
Limit:	Reconnection after setting observation time ( $\geq 60s$ )	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min.	
<b>Frequency conditions</b>		
d) Start up for frequency range	<47,45 Hz for twice of setting observation time	>50,15 Hz for twice of setting observation time
Connection:	No connection	No connection
Limit:	No connection allowed	
e) In frequency range at start-up	$\geq 47,45$ Hz within twice of setting observation time	$\leq 51,15$ Hz within twice of setting observation time
Reconnection time [s]	62	61
Limit:	Connected after setting delay time ( $\geq 60s$ )	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min.	
f) In frequency range after frequency failure	$\geq 47,45$ Hz for twice of setting observation time	$\leq 51,15$ Hz for twice of setting observation time
Reconnection time [s]	61	62
Limit:	Reconnection after setting observation time ( $\geq 60s$ )	
Gradient:	For adjustable micro generators the maximum occurring active power gradient after connection respectively start generating electrical power is less than the configured maximum active power per minute Max gradient: 10%Pn/min.	



**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Short-circuit current contribution					
Short-circuit current parameters					
For a directly coupled micro-generator			For a Inverter micro-generator		
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	$I_p$	N/A	20ms	50,8	38,7
Initial Value of aperiodic current	A	N/A	100ms	50,6	36,3
Initial symmetrical short-circuit current*	$I_k$	N/A	250ms	50,3	57,3
Decaying (aperiodic) component of short circuit current*	$i_{DC}$	N/A	500ms	50,3	64,6
Reactance/Resistance Ratio of source*	X/R	N/A	Time to trip	0,526	In seconds

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Power Quality. Harmonic current emission					
micro-generator		SHP75-10			
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN61000-3-12 [%]	
				1 phase	3 phase
1st	109,086	100,000	Phase 1	-	-
2nd	0,598	0,548	Phase 1	8	8
3rd	1,907	1,748	Phase 1	21,6	N/A
4th	0,428	0,393	Phase 1	4	4
5th	0,565	0,518	Phase 1	10,7	10,7
6th	0,269	0,247	Phase 1	2,67	2,67
7th	0,239	0,219	Phase 1	7,2	7,2
8th	0,140	0,128	Phase 1	2	2
9th	0,289	0,265	Phase 1	3,8	N/A
10th	0,107	0,098	Phase 1	1,6	1,6
11th	0,151	0,139	Phase 1	3,1	3,1
12th	0,071	0,065	Phase 1	1,33	1,33
13th	0,123	0,113	Phase 1	2	2
14th	0,053	0,048	Phase 1	N/A	N/A
15th	0,082	0,075	Phase 1	N/A	N/A
16th	0,054	0,049	Phase 1	N/A	N/A
17th	0,158	0,145	Phase 1	N/A	N/A
18th	0,034	0,031	Phase 1	N/A	N/A
19th	0,118	0,108	Phase 1	N/A	N/A
20th	0,031	0,028	Phase 1	N/A	N/A
21th	0,047	0,043	Phase 1	N/A	N/A
22th	0,029	0,027	Phase 1	N/A	N/A
23th	0,086	0,078	Phase 1	N/A	N/A
24th	0,028	0,026	Phase 1	N/A	N/A
25th	0,071	0,065	Phase 1	N/A	N/A
26th	0,028	0,025	Phase 1	N/A	N/A
27th	0,043	0,039	Phase 1	N/A	N/A
28th	0,023	0,021	Phase 1	N/A	N/A
29th	0,055	0,050	Phase 1	N/A	N/A
30th	0,027	0,025	Phase 1	N/A	N/A
31th	0,045	0,041	Phase 1	N/A	N/A
32th	0,031	0,028	Phase 1	N/A	N/A
33th	0,033	0,031	Phase 1	N/A	N/A
34th	0,025	0,023	Phase 1	N/A	N/A
35th	0,051	0,046	Phase 1	N/A	N/A
36th	0,039	0,035	Phase 1	N/A	N/A
37th	0,037	0,034	Phase 1	N/A	N/A
38th	0,036	0,033	Phase 1	N/A	N/A
39th	0,043	0,039	Phase 1	N/A	N/A
40th	0,056	0,051	Phase 1	N/A	N/A
THD <sub>40</sub>	-	2,03	Phase 1	13	13
PWHD	-	0,001	Phase 1	22	22

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Power Quality. Harmonic current emission					
micro-generator		SHP75-10			
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN61000-3-12 [%]	
				1 phase	3 phase
1st	109,061	100,000	Phase 2	-	-
2nd	0,624	0,572	Phase 2	8	8
3rd	1,821	1,670	Phase 2	21,6	N/A
4th	0,473	0,434	Phase 2	4	4
5th	0,555	0,509	Phase 2	10,7	10,7
6th	0,205	0,188	Phase 2	2,67	2,67
7th	0,167	0,153	Phase 2	7,2	7,2
8th	0,142	0,130	Phase 2	2	2
9th	0,290	0,265	Phase 2	3,8	N/A
10th	0,133	0,122	Phase 2	1,6	1,6
11th	0,144	0,132	Phase 2	3,1	3,1
12th	0,128	0,117	Phase 2	1,33	1,33
13th	0,149	0,137	Phase 2	2	2
14th	0,072	0,066	Phase 2	N/A	N/A
15th	0,104	0,096	Phase 2	N/A	N/A
16th	0,048	0,044	Phase 2	N/A	N/A
17th	0,167	0,153	Phase 2	N/A	N/A
18th	0,040	0,037	Phase 2	N/A	N/A
19th	0,120	0,110	Phase 2	N/A	N/A
20th	0,037	0,034	Phase 2	N/A	N/A
21th	0,064	0,059	Phase 2	N/A	N/A
22th	0,040	0,037	Phase 2	N/A	N/A
23th	0,083	0,076	Phase 2	N/A	N/A
24th	0,037	0,034	Phase 2	N/A	N/A
25th	0,079	0,072	Phase 2	N/A	N/A
26th	0,028	0,026	Phase 2	N/A	N/A
27th	0,050	0,045	Phase 2	N/A	N/A
28th	0,024	0,022	Phase 2	N/A	N/A
29th	0,055	0,051	Phase 2	N/A	N/A
30th	0,028	0,025	Phase 2	N/A	N/A
31th	0,058	0,053	Phase 2	N/A	N/A
32th	0,041	0,038	Phase 2	N/A	N/A
33th	0,056	0,051	Phase 2	N/A	N/A
34th	0,058	0,053	Phase 2	N/A	N/A
35th	0,035	0,032	Phase 2	N/A	N/A
36th	0,040	0,037	Phase 2	N/A	N/A
37th	0,043	0,039	Phase 2	N/A	N/A
38th	0,031	0,029	Phase 2	N/A	N/A
39th	0,034	0,031	Phase 2	N/A	N/A
40th	0,032	0,030	Phase 2	N/A	N/A
THD <sub>40</sub>	-	1,97	Phase 2	13	13
PWHD	-	0,001	Phase 2	22	22

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Power Quality. Harmonic current emission					
micro-generator		SHP75-10			
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN61000-3-12 [%]	
				1 phase	3 phase
1st	109,104	100,000	Phase 3	-	-
2nd	0,617	0,566	Phase 3	8	8
3rd	1,850	1,696	Phase 3	21,6	N/A
4th	0,391	0,358	Phase 3	4	4
5th	0,537	0,492	Phase 3	10,7	10,7
6th	0,183	0,167	Phase 3	2,67	2,67
7th	0,163	0,150	Phase 3	7,2	7,2
8th	0,142	0,130	Phase 3	2	2
9th	0,279	0,256	Phase 3	3,8	N/A
10th	0,120	0,110	Phase 3	1,6	1,6
11th	0,140	0,128	Phase 3	3,1	3,1
12th	0,098	0,090	Phase 3	1,33	1,33
13th	0,136	0,124	Phase 3	2	2
14th	0,052	0,048	Phase 3	N/A	N/A
15th	0,081	0,074	Phase 3	N/A	N/A
16th	0,045	0,041	Phase 3	N/A	N/A
17th	0,161	0,147	Phase 3	N/A	N/A
18th	0,040	0,037	Phase 3	N/A	N/A
19th	0,106	0,097	Phase 3	N/A	N/A
20th	0,028	0,026	Phase 3	N/A	N/A
21th	0,048	0,044	Phase 3	N/A	N/A
22th	0,029	0,027	Phase 3	N/A	N/A
23th	0,071	0,065	Phase 3	N/A	N/A
24th	0,029	0,027	Phase 3	N/A	N/A
25th	0,057	0,052	Phase 3	N/A	N/A
26th	0,025	0,023	Phase 3	N/A	N/A
27th	0,043	0,039	Phase 3	N/A	N/A
28th	0,020	0,019	Phase 3	N/A	N/A
29th	0,042	0,038	Phase 3	N/A	N/A
30th	0,022	0,020	Phase 3	N/A	N/A
31th	0,045	0,041	Phase 3	N/A	N/A
32th	0,032	0,029	Phase 3	N/A	N/A
33th	0,048	0,044	Phase 3	N/A	N/A
34th	0,051	0,047	Phase 3	N/A	N/A
35th	0,043	0,039	Phase 3	N/A	N/A
36th	0,047	0,043	Phase 3	N/A	N/A
37th	0,044	0,040	Phase 3	N/A	N/A
38th	0,037	0,034	Phase 3	N/A	N/A
39th	0,030	0,028	Phase 3	N/A	N/A
40th	0,031	0,029	Phase 3	N/A	N/A
THD <sub>40</sub>	-	1,96	Phase 3	13	13
PWHD	-	0,001	Phase 3	22	22

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Power Quality. Harmonic current emission					
micro-generator		STPS60-10			
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN61000-3-12 [%]	
				1 phase	3 phase
1st	106,894	100,000	Phase 1	-	-
2nd	0,111	0,104	Phase 1	8	8
3rd	0,042	0,040	Phase 1	21,6	N/A
4th	0,071	0,066	Phase 1	4	4
5th	0,062	0,058	Phase 1	10,7	10,7
6th	0,045	0,042	Phase 1	2,67	2,67
7th	0,044	0,041	Phase 1	7,2	7,2
8th	0,039	0,037	Phase 1	2	2
9th	0,159	0,148	Phase 1	3,8	N/A
10th	0,050	0,047	Phase 1	1,6	1,6
11th	0,100	0,094	Phase 1	3,1	3,1
12th	0,034	0,032	Phase 1	1,33	1,33
13th	0,123	0,115	Phase 1	2	2
14th	0,028	0,026	Phase 1	N/A	N/A
15th	0,033	0,031	Phase 1	N/A	N/A
16th	0,043	0,040	Phase 1	N/A	N/A
17th	0,194	0,182	Phase 1	N/A	N/A
18th	0,024	0,022	Phase 1	N/A	N/A
19th	0,131	0,122	Phase 1	N/A	N/A
20th	0,021	0,019	Phase 1	N/A	N/A
21th	0,021	0,020	Phase 1	N/A	N/A
22th	0,013	0,012	Phase 1	N/A	N/A
23th	0,107	0,100	Phase 1	N/A	N/A
24th	0,014	0,014	Phase 1	N/A	N/A
25th	0,088	0,083	Phase 1	N/A	N/A
26th	0,013	0,012	Phase 1	N/A	N/A
27th	0,025	0,023	Phase 1	N/A	N/A
28th	0,012	0,012	Phase 1	N/A	N/A
29th	0,066	0,062	Phase 1	N/A	N/A
30th	0,013	0,013	Phase 1	N/A	N/A
31th	0,054	0,050	Phase 1	N/A	N/A
32th	0,022	0,021	Phase 1	N/A	N/A
33th	0,037	0,035	Phase 1	N/A	N/A
34th	0,036	0,034	Phase 1	N/A	N/A
35th	0,043	0,040	Phase 1	N/A	N/A
36th	0,017	0,016	Phase 1	N/A	N/A
37th	0,060	0,056	Phase 1	N/A	N/A
38th	0,067	0,063	Phase 1	N/A	N/A
39th	0,055	0,051	Phase 1	N/A	N/A
40th	0,065	0,061	Phase 1	N/A	N/A
THD <sub>40</sub>	-	0,431	Phase 1	13	13
PWHD	-	0,002	Phase 1	22	22

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Power Quality. Harmonic current emission					
micro-generator		STPS60-10			
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN61000-3-12 [%]	
				1 phase	3 phase
1st	106,835	100,000	Phase 2	-	-
2nd	0,293	0,275	Phase 2	8	8
3rd	0,036	0,034	Phase 2	21,6	N/A
4th	0,093	0,087	Phase 2	4	4
5th	0,047	0,044	Phase 2	10,7	10,7
6th	0,062	0,058	Phase 2	2,67	2,67
7th	0,029	0,027	Phase 2	7,2	7,2
8th	0,041	0,038	Phase 2	2	2
9th	0,177	0,165	Phase 2	3,8	N/A
10th	0,061	0,057	Phase 2	1,6	1,6
11th	0,110	0,103	Phase 2	3,1	3,1
12th	0,038	0,035	Phase 2	1,33	1,33
13th	0,132	0,124	Phase 2	2	2
14th	0,036	0,033	Phase 2	N/A	N/A
15th	0,032	0,030	Phase 2	N/A	N/A
16th	0,028	0,027	Phase 2	N/A	N/A
17th	0,217	0,203	Phase 2	N/A	N/A
18th	0,022	0,021	Phase 2	N/A	N/A
19th	0,136	0,127	Phase 2	N/A	N/A
20th	0,017	0,016	Phase 2	N/A	N/A
21th	0,019	0,018	Phase 2	N/A	N/A
22th	0,019	0,018	Phase 2	N/A	N/A
23th	0,107	0,100	Phase 2	N/A	N/A
24th	0,017	0,016	Phase 2	N/A	N/A
25th	0,083	0,078	Phase 2	N/A	N/A
26th	0,011	0,011	Phase 2	N/A	N/A
27th	0,023	0,022	Phase 2	N/A	N/A
28th	0,013	0,012	Phase 2	N/A	N/A
29th	0,064	0,060	Phase 2	N/A	N/A
30th	0,013	0,012	Phase 2	N/A	N/A
31th	0,053	0,049	Phase 2	N/A	N/A
32th	0,031	0,029	Phase 2	N/A	N/A
33th	0,050	0,047	Phase 2	N/A	N/A
34th	0,064	0,060	Phase 2	N/A	N/A
35th	0,065	0,061	Phase 2	N/A	N/A
36th	0,066	0,062	Phase 2	N/A	N/A
37th	0,047	0,044	Phase 2	N/A	N/A
38th	0,027	0,025	Phase 2	N/A	N/A
39th	0,033	0,031	Phase 2	N/A	N/A
40th	0,034	0,031	Phase 2	N/A	N/A
THD <sub>40</sub>	-	0,515	Phase 2	13	13
PWHD	-	0,002	Phase 2	22	22

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Power Quality. Harmonic current emission					
micro-generator		STPS60-10			
Harmonic order n	Current Magnitude [A] at 100% rated output power	% of Fundamental	Phase	Harmonic current limit EN61000-3-12 [%]	
				1 phase	3 phase
1st	106,893	100,000	Phase 3	-	-
2nd	0,197	0,184	Phase 3	8	8
3rd	0,034	0,032	Phase 3	21,6	N/A
4th	0,072	0,068	Phase 3	4	4
5th	0,032	0,030	Phase 3	10,7	10,7
6th	0,056	0,053	Phase 3	2,67	2,67
7th	0,033	0,031	Phase 3	7,2	7,2
8th	0,038	0,036	Phase 3	2	2
9th	0,046	0,043	Phase 3	3,8	N/A
10th	0,058	0,054	Phase 3	1,6	1,6
11th	0,093	0,087	Phase 3	3,1	3,1
12th	0,038	0,036	Phase 3	1,33	1,33
13th	0,133	0,124	Phase 3	2	2
14th	0,026	0,024	Phase 3	N/A	N/A
15th	0,027	0,025	Phase 3	N/A	N/A
16th	0,033	0,031	Phase 3	N/A	N/A
17th	0,217	0,203	Phase 3	N/A	N/A
18th	0,032	0,030	Phase 3	N/A	N/A
19th	0,139	0,130	Phase 3	N/A	N/A
20th	0,015	0,014	Phase 3	N/A	N/A
21th	0,017	0,016	Phase 3	N/A	N/A
22th	0,019	0,018	Phase 3	N/A	N/A
23th	0,113	0,105	Phase 3	N/A	N/A
24th	0,016	0,015	Phase 3	N/A	N/A
25th	0,082	0,077	Phase 3	N/A	N/A
26th	0,012	0,011	Phase 3	N/A	N/A
27th	0,023	0,021	Phase 3	N/A	N/A
28th	0,013	0,012	Phase 3	N/A	N/A
29th	0,066	0,062	Phase 3	N/A	N/A
30th	0,012	0,011	Phase 3	N/A	N/A
31th	0,055	0,051	Phase 3	N/A	N/A
32th	0,025	0,023	Phase 3	N/A	N/A
33th	0,040	0,037	Phase 3	N/A	N/A
34th	0,048	0,044	Phase 3	N/A	N/A
35th	0,064	0,060	Phase 3	N/A	N/A
36th	0,065	0,061	Phase 3	N/A	N/A
37th	0,059	0,056	Phase 3	N/A	N/A
38th	0,045	0,042	Phase 3	N/A	N/A
39th	0,026	0,025	Phase 3	N/A	N/A
40th	0,036	0,034	Phase 3	N/A	N/A
THD <sub>40</sub>	-	0,438	Phase 3	13	13
PWHD	-	0,002	Phase 3	22	22

**Appendix E Type Verification Test Report**

Extract from test report according to EN 50438

Nr. 14TH0075\_EN50438\_1

Voltage fluctuation and Flicker.					
	Maximum permissible flicker and voltage fluctuation as per EN 61000-3-11				
Value	Pst	Plt 2 hours	d(t) <sub>500ms</sub>	dc	dmax
Limit	1,0	0,65	3,3%	3,3%	4%
Test value	0,086	0,086	3,3%	3,3%	4,0%

DC-Injection.				
Protection limit	Tested at four power levels, limit 0,5% of IAC <sub>nom</sub> (543mA)			
Output power	~20%	~50%	75%	~100%
Max. test value (phase L1) [mA]	1,48	5,09	3,85	13,02
Max. test value (phase L2) [mA]	25,76	24,35	23,91	19,44
Max. test value (phase L3) [mA]	38,99	37,64	39,97	38,37